



# 2023 SECTION 22 SUMMARY REPORT

HURON WOODS  
DRINKING WATER SYSTEM

For the period of:  
**JANUARY 1, 2023 TO DECEMBER 31, 2023**

Prepared for the Town of South Bruce Peninsula by the Ontario Clean Water Agency



This report was prepared in accordance with the requirements of [O.Reg 170/03, Schedule 22, Summary Reports for Municipalities](#) for the following system and reporting period:

<b>Drinking-Water System Number:</b>	220007775
<b>Drinking-Water System Name:</b>	Huron Woods Drinking Water System
<b>Drinking-Water System Owner:</b>	Town of South Bruce Peninsula
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2023 – December 31, 2023

## 1. Issue(s) of Non-Compliance

A Ministry of Environment, Conservation and Parks (MECP) Drinking Water System Inspection was conducted on September 28, 2023 for the period covering November 2, 2022 to September 28, 2023. On November 6, 2023 the Inspection Report was issued and a final inspection rating of 100% was received.

The following is a summary of non-compliances noted in the MECP Inspection Report, as well as the duration and the measures that were taken to correct the non-compliance. If any self-reported non-compliances were included in the inspection report, they will be noted in Table 1.

**Table 1. Non-Compliances and Corrective Actions noted in the 2022/2023 MECP Inspection Report**

Non-Compliance(s)	Duration	Required Actions & Corrective Actions
N/A	N/A	N/A

The following table (Table 2) is a summary of any incidents that the Operating Authority interpreted as instances where any requirements of the Act, the regulations, the system's approval, drinking water works permit (DWWP), municipal drinking water licence (MDWL), and any orders applicable were not met. The Operating Authority reported the following incidents to the MECP and confirmation of whether the incidents are considered non-compliances are noted in the MECP Inspection Report and included in Table 1.

**Table 2. Self-Reported Incidents and Corrective Actions for the Reporting Period**

Incident	Duration	Corrective Actions
N/A	N/A	N/A

For information on any Adverse Water Quality Incident(s) that may have occurred during the reporting period, please refer to the Huron Woods Drinking Water System Annual Report (Section 11).

## 2. Assessment of Flowrates and Quantity of Water Supplied

The following tables summarize the quantities and flow rates of water supplied during the reporting period, including monthly averages and maximum daily flows as well as a comparison to the rated capacity and flow rates approved in the system’s approval, DWWP or MDWL.

### 2.1 Treated Water

<b>Municipal Drinking Water License (MDWL):</b>	094-103 (Issue Number: 4)
<b>Allowable Rated Capacity:</b>	743 m <sup>3</sup> /day
<b>Allowable Flowrate into Treatment System:</b>	N/A

As per the MDWL, the maximum daily volume of treated water that flows from the treatment subsystem to the distribution system shall not exceed the listed rated capacity. However, the MDWL allows a system to be operated temporarily at a maximum daily volume and/or a maximum flowrate above the values set out in the MDWL for the purposes of fighting a large fire or for the maintenance of the drinking water system.

**Table 3. Treated Water Annual and Monthly Average and Maximum Flows with Comparison to Rated Capacity and Total Volume for 2023**

Treated Water Flow					
Timeframe	Average Flow (m <sup>3</sup> /day)	Percent of Rated Capacity	Maximum Flow (m <sup>3</sup> /day)	Percent of Rated Capacity	Total Volume (m <sup>3</sup> )
January	60.2	8.1%	68.3	9.2%	1,867
February	73.8	9.9%	109.3	14.7%	2,067
March	66.2	8.9%	75.8	10.2%	2,054
April	69.6	9.4%	77.5	10.4%	2,087
May	83.1	11.2%	115.4	15.5%	2,575
June	94.0	12.7%	115.6	15.6%	2,822
July	85.8	11.5%	128.4	17.3%	2,661
August	78.2	10.5%	92.4	12.4%	2,426
September	72.5	9.8%	84.8	11.4%	2,176
October	74.3	10.0%	84.7	11.4%	2,303
November	74.0	10.0%	85.5	11.5%	2,220
December	77.1	10.4%	87.3	11.7%	2,390
<b>2023</b>	<b>75.8</b>	<b>10.2%</b>	<b>128.4</b>	<b>17.3%</b>	<b>27,646</b>

A review of flow information for the reporting period indicates that the drinking water system operated within the rated capacity specified in the MDWL, for the maximum treated volume of treated water that flows from the treatment subsystem to the distribution system.



**Table 4. Treated Water Annual and Monthly Average and Maximum Flowrates for 2023**

<b>Treated Water Flowrate</b>		
<b>Timeframe</b>	<b>Average Flowrate (L/sec)</b>	<b>Maximum Flowrate (L/sec)</b>
January	0.70	3.76
February	0.85	4.02
March	0.76	3.70
April	0.81	3.70
May	0.94	4.05
June	1.09	4.36
July	0.99	4.52
August	0.90	4.68
September	0.84	4.29
October	0.86	4.40
November	0.86	4.20
December	0.89	4.04
<b>2023</b>	<b>0.88</b>	<b>4.68</b>

The applicable MDWL for the reporting period did not list a maximum allowable limit for the flowrate of water that flows into a treatment subsystem. A summary of flowrates of water that flows into the treatment system can be found in Table 6.

## 2.2 Raw Water

<b>Permit to Take Water Number:</b>	5437-BTFNDL
<b>Allowable Maximum Raw Water Volume - Well 6:</b>	457 m <sup>3</sup> /day
<b>Allowable Maximum Raw Water Flowrate - Well 6:</b>	318 L/min (5.3 L/sec)

As per the PTTW, water shall only be taken from the specified source(s) and at the rates and amounts taken as specified in the permit.

**Table 4. Raw Water (Well 6) Monthly Average, Maximum Flow and Total Volume for 2023**

Raw Water Flow – Well 6					
Timeframe	Average Flow (m <sup>3</sup> /day)	Percent of Allowable Volume	Maximum Flow (m <sup>3</sup> /day)	Percent of Allowable Volume	Total Volume (m <sup>3</sup> )
January	64.4	14.1%	111.4	24.4%	1,998
February	78.3	17.1%	116.6	25.5%	2,192
March	70.0	15.3%	117.8	25.8%	2,169
April	73.5	16.1%	117.7	25.8%	2,206
May	86.2	18.9%	139.7	30.6%	2,673
June	97.0	21.2%	155.5	34.0%	2,909
July	91.7	20.1%	141.3	30.9%	2,844
August	82.4	18.0%	138.5	30.3%	2,555
September	77.2	16.9%	119.5	26.1%	2,315
October	76.5	16.7%	122.2	26.7%	2,371
November	79.0	17.3%	124.7	27.3%	2,369
December	79.9	17.5%	132.9	29.1%	2,476
<b>2023</b>	<b>79.7</b>	<b>17.4%</b>	<b>155.5</b>	<b>34.0%</b>	<b>29,075</b>

A review of flow information for the reporting period indicates that the system operated within the PTTW's maximum allowable daily raw water volume for Well 6.

**Table 6. Raw Water (Well 6) Annual and Monthly Average and Maximum Flowrates for 2023**

<b>Raw Water Flowrate – Well 6</b>		
<b>Timeframe</b>	<b>Average Flowrate (L/sec)</b>	<b>Maximum Flowrate (L/sec)</b>
January	4.48	5.14
February	4.51	5.19
March	4.49	5.03
April	4.47	5.10
May	4.54	5.10
June	4.53	5.00
July	4.49	5.10
August	4.54	5.08
September	4.54	5.15
October	4.60	5.10
November	4.60	5.20
December	4.55	5.10
<b>2023</b>	<b>4.53</b>	<b>5.20</b>

A review of flow information for the reporting period indicates that the system operated within the PTTW’s maximum allowable raw water flowrate for Well 6.



# 2023 SECTION 11 ANNUAL REPORT

HURON WOODS  
DRINKING WATER SYSTEM

For the period of:  
**JANUARY 1, 2023 TO DECEMBER 31, 2023**

Prepared for the Town of South Bruce Peninsula by the Ontario Clean Water Agency



Drinking Water System Regulation: O. Reg 170/03  
 Section 11 Annual Report: January 1, 2023 to December 31, 2023  
 Town of South Bruce Peninsula: Huron Woods Drinking Water System

This report was prepared in accordance with the requirements of [O.Reg 170/03, Section 11, Annual reports](#) for the following system and reporting period:

<b>Drinking Water System Number:</b>	220007775
<b>Drinking Water System Name:</b>	Huron Woods Drinking Water System
<b>Drinking Water System Owner:</b>	Town of South Bruce Peninsula
<b>Drinking Water System Category:</b>	Large Municipal Residential
<b>Reporting Period:</b>	January 1, 2023 – December 31, 2023

**Does your Drinking Water System serve more than 10,000 people?**

No

**Is your Annual Report available to the public at no charge on a website on the Internet?**

Yes

*Note: If a large municipal residential system serves more than 10,000 people, the owner of the system shall ensure that a copy of every report prepared under this section is available to the public at no charge on a website on the Internet. O. Reg. 170/03, Section 11. (10)*

**Location where Summary Report required under O. Reg 170/03, Schedule 22 will be available for inspection. (O. Reg 170/03, Section 11.(6)(5)):**

- Town of South Bruce Peninsula, 315 George Street, Wiarton ON, N0H 2T0
- <https://www.southbrucepeninsula.com/en/town-hall/water-and-sewer-reports.aspx>

**List all Drinking Water Systems (if any), which receive all of their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
N/A	N/A

**Did you provide a copy of your annual report to all Drinking Water System owners that are connected to you and to whom you provide all of its drinking water?**

N/A

**How system users are notified that the annual report is available, and is free of charge:**

- |                                     |  |
|-------------------------------------|--|
| <input checked="" type="checkbox"/> | Public access/notice via the web             |
| <input checked="" type="checkbox"/> | Public access/notice via Government Office   |
| <input type="checkbox"/>            | Public access/notice via a newspaper         |
| <input checked="" type="checkbox"/> | Public access/notice via Public Request      |
| <input type="checkbox"/>            | Public access/notice via a Public Library    |
| <input type="checkbox"/>            | Public access/notice via other method: _____ |



*Note: The owner of a drinking water system shall ensure that a copy of an annual report for the system is given, without charge, to every person who requests a copy. ((O.Reg 170/03, Section 11.(7)).*

**Description of Drinking Water System (O.Reg 170/03, Section 11.(6)(a)):**

The Huron Woods Drinking Water System is classified as a Class II Water Treatment and Class I Water Distribution and categorized as a Large Municipal Residential Drinking Water System, servicing an approximate population of 230 persons. The Huron Woods Drinking Water System is owned by the Corporation of the Town of South Bruce Peninsula and operated by the Ontario Clean Water Agency (OCWA) in South Bruce Peninsula, Ontario.

The Huron Woods Drinking Water System is supplied by a deep drilled overburden GUDI well (Well 6). The well pumphouse houses the treatment and control facilities which include:

- Sodium hypochlorite oxidation/disinfection system (iron oxidation prior to filtration, primary disinfection and post chlorination)
- Iron and Manganese Removal (via greensand filters)
- Cartridge filtration (as pretreatment for the UV disinfection system)
- Ultra Violet Disinfection System
- Residuals Management (backwash wastewater holding tank)
- Reservoir/clearwell (for storage and for achieving the required contact time)
- Hydropneumatic pressure tanks (to maintain pressure)
- SCADA system (to control process equipment functions within the plant)
- Diesel generator set (back-up power supply)

**List of water treatment chemicals used by the system during the reporting period (O.Reg 170/03, Section 11.(6)(a)):**

- Sodium Hypochlorite 12%

**Significant expenses were incurred to:**

- |                                     |                                       |
|-------------------------------------|---------------------------------------|
| <input checked="" type="checkbox"/> | Install required equipment            |
| <input checked="" type="checkbox"/> | Repair required equipment             |
| <input checked="" type="checkbox"/> | Replace required equipment            |
| <input type="checkbox"/>            | No significant expenses were incurred |

**Description of major expenses during the reporting period to install, repair or replace required equipment (O.Reg 170/03, Section 11.(6)(e)):**

- Reservoir inspection and cleaning
- Replacement filter cartridges
- Replacement UV sensor

**Summary of any reports/notices submitted to the Ministry and/or Spills Action Centre in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 during the reporting period, including a description of any corrective actions taken under Schedule 17 or 18 (O. Reg 170/03, Section 11.(6)(b),(d):**

Incident Date (yyyy/mm/dd)	Parameter/ Notice of	Result & Unit	Summary of Reporting, Corrective Actions & Resolution
N/A	N/A	N/A	N/A

**Table 1. Microbiological testing done under the Schedule 11 of Regulation 170/03 during this reporting period (O.Reg 170/03, Section 11.(6)(c)).**

Location	Number of Samples	Range of E. Coli or Fecal Results		Range of Total Coliform Results		Number of HPC Samples	Range of HPC Samples	
		Min.	Max.	Min.	Max.		Min.	Max.
Raw – Well 6 <sup>1a</sup>	52	0	0	0	0	N/A	N/A	N/A
Treated <sup>1b</sup>	52	0	0	0	0	52	0	4
Distribution <sup>1c</sup>	104	0	0	0	0	52	0	1

Note: HPC = Heterotrophic Plate Count

Note: Units for E.Coli or Fecal Results are cfu/100 mL, units for Total Coliform Results are cfu/100 mL, units for HPC results are cfu/1mL

<sup>1a</sup>O.Reg 170/03, Schedule 10-4. (1)(3) requires for a large municipal residential system that a water sample is taken at least once every week from the drinking water system’s raw water, before any treatment is applied to the water and tested for E.Coli and total coliforms.

<sup>1b</sup>O.Reg 170/03, Schedule 10-3 requires for a large municipal residential system that a treated water sample is taken at least once every week and tested for E.Coli, total coliforms and general bacteria population expressed as colony counts on a heterotrophic count (HPC).

<sup>1c</sup>O.Reg. 170/03 Schedule 10-2.(1)(2)(3) requires that a system that serves 100,000 people or less, at least eight distribution samples, plus one additional sample for every 1,000 people served by the system to be taken every month, with at least one of the samples being taken in each week and be tested for E.Coli, Total Coliforms. At least 25 percent of the samples required must be tested for general bacteria population expressed as colony counts on heterotrophic plate count (HPC). The number of people served by the system is 230 (as confirmed with the Owner on March 9, 2023), and therefore requires at minimum eight per month.

**Table 2. Operational testing done under Schedule 7 of Regulation 170/03 during the period covered by this Annual Report (O. Reg 170/03, Section 11.(6)(c)).**

Parameter & Location	Number of Samples	Range of Results	
		Min.	Max.
Turbidity, Filter (NTU) <sup>2a</sup>	8760	0.01	0.48
Free Chlorine Residual, Treated Water (mg/L) <sup>2b</sup>	8760	0.60	2.00

Free Chlorine Residual, Distribution Water (mg/L) <sup>2c</sup>	416	0.71	2.00
---	-----	------	------

Note: The number of samples used for continuous monitoring units is 8760.

<sup>2a</sup>If a drinking water system obtains water from a raw water supply that is surface water (or well water deemed as GUDI) and the system provides filtration, subsection 7-3(1) does not apply and the owner of a system shall ensure that sampling and testing for turbidity is carried out by continuous monitoring equipment on each filter effluent line (O.Reg.170/03, Schedule 7-3.(2)(b))

<sup>2b</sup>O.Reg 170/03 Schedule 7-2.(1) requires a drinking water system that provides chlorination for primary disinfection to sample and test for free chlorine residual with continuous monitoring equipment in the treatment process at or near a location where the intended contact time has just been completed.

<sup>2c</sup>O.Reg 170/03 Schedule 7-2.(3) requires a large municipal residential system that provides secondary disinfection to take at least seven distribution samples each week and immediately tested for free chlorine residual, if the system provides chlorination and does not provide chloramination. Sampling for distribution free chlorine residual at the Huron Woods Drinking Water is taken twice a week.

**Table 3. Summary of additional testing and sampling results carried out in accordance with the requirement of an approval, municipal drinking water licence or order (including OWRA) or other legal instrument. (O. Reg 170/03, Section 11.(6)(c))**

Legal Instrument & Issue Date (yyyy/mm/dd)	Parameter	Date Sampled	Number of Samples	Annual Average	Allowable Annual Average
2020-03-06 MDWL 094-103 (Issue 4)	Total Suspended Solids (Filter backwash)	2023 (Monthly)	12	2.50	25 mg/L
2020-03-06 MDWL 094-103 (Issue 4)	Total Chlorine Residual (Filter backwash)	2023 (Monthly)	12	0.014	0.02 mg/L

**Table 4. Summary of Inorganic parameters tested during this reporting period or the most recent sample results (O.Reg 170/03, Section 11.(6)(c))**

Parameter & Location	Sample Date <sup>4a</sup> (yyyy/mm/dd)	Sample Result	Maximum Allowable Concentration (MAC)	Exceedance of MAC
Antimony: Sb (µg/L) - TW	2023/01/03	<MDL 0.6	6.0	No
Arsenic: As (µg/L) - TW	2023/01/03	<MDL 0.2	10.0	No
Barium: Ba (µg/L) - TW	2023/01/03	21.3	1000.0	No
Boron: B (µg/L) - TW	2023/01/03	15.0	5000.0	No
Cadmium: Cd (µg/L) - TW	2023/01/03	0.017	5.0	No

Drinking Water System Regulation: O. Reg 170/03  
 Section 11 Annual Report: January 1, 2023 to December 31, 2023  
 Town of South Bruce Peninsula: Huron Woods Drinking Water System

Chromium: Cr (µg/L) - TW	2023/01/03	0.26	50.0	No
Mercury: Hg (µg/L) - TW	2023/01/03	<MDL 0.01	1.0	No
Selenium: Se (µg/L) - TW	2023/01/03	0.34	50.0	No
Uranium: U (µg/L) - TW	2023/01/03	0.028	20.0	No
Fluoride (mg/L) - TW	2022/01/04 <sup>4b</sup>	0.15	1.5	No
Nitrite (mg/L) - TW	2023/01/09	<MDL 0.003	1.0	No
Nitrite (mg/L) - TW	2023/04/03	<MDL 0.003	1.0	No
Nitrite (mg/L) - TW	2023/07/04	<MDL 0.003	1.0	No
Nitrite (mg/L) - TW	2023/10/02	<MDL 0.003	1.0	No
Nitrate (mg/L) - TW	2023/01/09	<MDL 0.006	10.0	No
Nitrate (mg/L) - TW	2023/04/03	<MDL 0.006	10.0	No
Nitrate (mg/L) - TW	2023/07/04	0.008	10.0	No
Nitrate (mg/L) - TW	2023/10/02	0.007	10.0	No

Note: MDL = Minimum Detection Limit, TW = Treated Water

<sup>4a</sup>The owner of a large municipal residential system that obtains water from a raw water supply that is surface water (or well water deemed as GUDI) shall ensure that at least one water sample for inorganics is taken every 12 months (O.Reg 170/03, Schedule 13-2.(1)). The last set of samples were collected and tested in 2023, the next set of samples are scheduled to be collected and tested in 2024.

<sup>4b</sup>Fluoride is reportable every 60 months. The most recent Fluoride samples were tested in 2022, the next set of samples is scheduled to be tested in 2027.

Parameter & Location	Sample Date (yyyy/mm/dd)	Sample Result	Aesthetic Objective (AO)	Exceedance	
				AO	> 20 mg/L
Sodium: Na (mg/L) - TW	2022/01/04 <sup>4c</sup>	7.57	200	No	No

Note: MDL = Minimum Detection Limit, TW = Treated Water

Note: There is no regulatory Maximum Allowable Concentration (MAC) for Sodium. The aesthetic objective (AO) for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

<sup>4c</sup>Sodium is reportable every 60 months. The most recent Sodium samples were tested in 2022, the next set of reportable samples is scheduled to be tested in 2027.

**Table 5: Summary of lead testing under Schedule 15.1 during this reporting period (O.Reg 170/03, Section 11.(6)(g))**

Location/Type & Parameter	Number of Samples <sup>5a</sup>	Range of Results		Number of Lead Exceedances (MAC = 10 µ/L)
		Min.	Max.	
<b>Period: January 1 to April 15</b>				
Plumbing – Lead (µg/L) <sup>5b</sup>	N/A	N/A	N/A	N/A



Drinking Water System Regulation: O. Reg 170/03  
 Section 11 Annual Report: January 1, 2023 to December 31, 2023  
 Town of South Bruce Peninsula: Huron Woods Drinking Water System

Distribution – Lead (µg/L) <sup>5c</sup>	N/A	N/A	N/A	N/A
Distribution – Alkalinity (mg/L as CaCO <sub>3</sub> )	2	257	274	N/A
Distribution – pH	2	7.83	7.86	N/A
<b>Period: June 15 to October 15</b>				
Plumbing – Lead (µg/L) <sup>5b</sup>	N/A	N/A	N/A	N/A
Distribution – Lead (µg/L) <sup>5c</sup>	N/A	N/A	N/A	N/A
Distribution – Alkalinity (mg/L as CaCO <sub>3</sub> )	2	268	272	N/A
Distribution – pH	2	7.60	7.73	N/A
<b>Period: December 15 to 31</b>				
Plumbing – Lead (µg/L) <sup>5b</sup>	N/A	N/A	N/A	N/A
Distribution – Lead (µg/L) <sup>5c</sup>	N/A	N/A	N/A	N/A
Distribution – Alkalinity (mg/L as CaCO <sub>3</sub> )	N/A	N/A	N/A	N/A
Distribution - pH	N/A	N/A	N/A	N/A

*Note: this is required for large municipal residential systems, small municipal residential systems or non-municipal year-round residential system. (O.Reg 170/03, Section 11.(6)(g))*

<sup>5a</sup>*This system follows a reduced sampling schedule (O.Reg. 170/03, Section 15.1.5). The number of sampling points for the system is based on the population served by the system. The number of people served by the system is 230 (as confirmed with the Owner on March 9, 2023), and therefore requires 1 distribution sampling points per sampling period. As best practice, OCWA takes 2 distribution samples per sampling period.*

<sup>5b</sup>*Plumbing samples are not applicable as this system qualifies for the plumbing exemption per O. Reg 170/03 Schedule 15.1-5 (9) (10).*

<sup>5c</sup>*This system follows a reduced sampling schedule (O.Reg 170/03, Section 15.1.5). Distribution lead samples are collected every 36 months. The most recent set of distribution lead samples were collected within the winter period of December 15, 2020 to April 15, 2021 and summer period of June 15, 2021 to October 15, 2021. The next set of distribution lead samples is scheduled to be collected within the winter period of December 15, 2023 to April 15, 2024 and summer period of June 15, 2024 to October 15, 2024.*

**Table 6: Summary of Organic parameters sampled during this reporting period or the most recent sample results (O.Reg 170/03, Section 11.(6)(c)).**

Parameter & Location	Sample Date <sup>6a</sup> (yyyy/mm/dd)	Sample Result	Maximum Allowable Concentration (MAC)	Exceedance of MAC
Alachlor (µg/L) - TW	2023/01/03	<MDL 0.02	5.0	No
Atrazine + N-dealkylated metabolites (µg/L) - TW	2023/01/03	<MDL 0.01	5.0	No
Azinphos-methyl (µg/L) - TW	2023/01/03	<MDL 0.05	20.0	No
Benzene (µg/L) - TW	2023/01/03	<MDL 0.32	1.0	No
Benzo(a)pyrene (µg/L) - TW	2023/01/03	<MDL 0.004	0.01	No

Drinking Water System Regulation: O. Reg 170/03  
 Section 11 Annual Report: January 1, 2023 to December 31, 2023  
 Town of South Bruce Peninsula: Huron Woods Drinking Water System

Parameter & Location	Sample Date <sup>6a</sup> (yyyy/mm/dd)	Sample Result	Maximum Allowable Concentration (MAC)	Exceedance of MAC
Bromoxynil (µg/L) - TW	2023/01/03	<MDL 0.33	5.0	No
Carbaryl (µg/L) - TW	2023/01/03	<MDL 0.05	90.0	No
Carbofuran (µg/L) - TW	2023/01/03	<MDL 0.01	90.0	No
Carbon Tetrachloride (µg/L) - TW	2023/01/03	<MDL 0.17	2.0	No
Chlorpyrifos (µg/L) - TW	2023/01/03	<MDL 0.02	90.0	No
Diazinon (µg/L) - TW	2023/01/03	<MDL 0.02	20.0	No
Dicamba (µg/L) - TW	2023/01/03	<MDL 0.2	120.0	No
1,2-Dichlorobenzene (µg/L) - TW	2023/01/03	<MDL 0.41	200.0	No
1,4-Dichlorobenzene (µg/L) - TW	2023/01/03	<MDL 0.36	5.0	No
1,2-Dichloroethane (µg/L) - TW	2023/01/03	<MDL 0.35	5.0	No
1,1-Dichloroethylene (µg/L) - TW	2023/01/03	<MDL 0.33	14.0	No
Dichloromethane (Methylene Chloride) (µg/L) - TW	2023/01/03	<MDL 0.35	50.0	No
2,4-Dichlorophenol (µg/L) - TW	2023/01/03	<MDL 0.15	900.0	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (µg/L) - TW	2023/01/03	<MDL 0.19	100.0	No
Diclofop-methyl (µg/L) - TW	2023/01/03	<MDL 0.4	9.0	No
Dimethoate (µg/L) - TW	2023/01/03	<MDL 0.06	20.0	No
Diquat (µg/L) - TW	2023/01/03	<MDL 1.0	70.0	No
Diuron (µg/L) - TW	2023/01/03	<MDL 0.03	150.0	No
Glyphosate (µg/L) - TW	2023/01/03	<MDL 1.0	280.0	No
Malathion (µg/L) - TW	2023/01/03	<MDL 0.02	190.0	No
Metolachlor (µg/L) - TW	2023/01/03	<MDL 0.01	50.0	No
Metribuzin (µg/L) - TW	2023/01/03	<MDL 0.02	80.0	No
Monochlorobenzene (Chlorobenzene) (µg/L) - TW	2023/01/03	<MDL 0.3	80.0	No
Paraquat (µg/L) - TW	2023/01/03	<MDL 1.0	10.0	No
PCB (µg/L) - TW	2023/01/03	<MDL 0.04	3.0	No
Pentachlorophenol (µg/L) - TW	2023/01/03	<MDL 0.15	60.0	No
Phorate (µg/L) - TW	2023/01/03	<MDL 0.01	2.0	No

Drinking Water System Regulation: O. Reg 170/03  
 Section 11 Annual Report: January 1, 2023 to December 31, 2023  
 Town of South Bruce Peninsula: Huron Woods Drinking Water System

Parameter & Location	Sample Date <sup>6a</sup> (yyyy/mm/dd)	Sample Result	Maximum Allowable Concentration (MAC)	Exceedance of MAC
Picloram (µg/L) - TW	2023/01/03	<MDL 1.0	190.0	No
Prometryne (µg/L) - TW	2023/01/03	<MDL 0.03	1.0	No
Simazine (µg/L) - TW	2023/01/03	<MDL 0.01	10.0	No
Terbufos (µg/L) - TW	2023/01/03	<MDL 0.01	1.0	No
Tetrachloroethylene (µg/L) - TW	2023/01/03	<MDL 0.35	10.0	No
2,3,4,6-Tetrachlorophenol (µg/L) - TW	2023/01/03	<MDL 0.2	100.0	No
Triallate (µg/L) - TW	2023/01/03	<MDL 0.01	230.0	No
Trichloroethylene (µg/L) - TW	2023/01/03	<MDL 0.44	5.0	No
2,4,6-Trichlorophenol (µg/L) - TW	2023/01/03	<MDL 0.25	5.0	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (µg/L) - TW	2023/01/03	<MDL 0.12	100.0	No
Trifluralin (µg/L) - TW	2023/01/03	<MDL 0.02	45.0	No
Vinyl Chloride (µg/L) - TW	2023/01/03	<MDL 0.17	1.0	No
Trihalomethane: Total (µg/L) Annual Average - DW	2023 (Quarterly)	66.8	100.0	No
HAA Total (µg/L) Annual Average - DW	2023 (Quarterly)	49.9	80.0	No

Note: DW = Distribution Water, TW = Treated Water, MDL = Minimum Detection Limit, MAC = Maximum Allowable Concentration

<sup>6a</sup>The owner of a large municipal residential system that obtains water from a raw water supply that is surface water (or well water deemed as GUDI) shall ensure that at least one water sample for organics is taken every 12 months (O.Reg 170/03, Schedule 13-4.(1)). The last set of samples were collected and tested in 2023, the next set of samples are scheduled to be collected and tested in 2024.

**Table 7: List of Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards for the reporting period.**

Parameter & Location	Sample Date (yyyy/mm/dd)	Sample Result
Trihalomethane: Total (µg/L) Annual Average - DW	2023 (Quarterly)	66.8
HAA Total (µg/L) Annual Average - DW	2023 (Quarterly)	49.9